***SCS Global Services** does hereby certify that an independent assessment has been conducted on behalf of:*

# Foshan Keruida Environmental Protection Material technology Co., Ltd

5 on No. 2 Jinkeng Road, Baini Town, Shanshui District, Foshan City, Guangdong, China

For the following product(s):

## Vinyl Tile:

Stone Plastic Composite Flooring *(Maximum thickness: 4mm)*
Stone Plastic Composite Flooring with pad *(Maximum thickness: 5mm)*

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

## FloorScore®

Indoor Air quality Certified to SCS-EC10.3-2014 v4.1
Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m$^3$ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-08342
Valid from: September 20, 2022 to September 30, 2023

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, http://www.scsglobalservices.com/certified-green-products-guide.

Stanley Mathuram, PE, Executive Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA